

PUBLIC/PRIVATE SCHOOL

STATE OF FLORIDA DEPARTMENT OF HEALTH COUNTY HEALTH DEPARTMENT PUBLIC/PRIVATE SCHOOL INSPECTION REPORT



Geocoded 25.944169/-80.122726

- PURPOSE:**
- ROUTINE
 - CONSTRUCT.
 - COMPLAINT
 - QA SURVEY
 - OTHER
 - REINSPECTION
 - CHANGE OF OWNER
 - CONSULTATION
 - EPIDEMIOLOGY
 - PREOPENING

TYPE: Public School

CENSUS	FEMALES	MALES
1984	1000	984

NAME Norman S. Edelpcup-Sunny Isles each K-8 Center
 ADDRESS 201 182 Drive CITY Sunny Isles Beach
 OWNER Miami-Dade County School Board ZIP 33160
 PERSON IN CHARGE Julio Fong PHONE (305) 933-6161
 E-MAIL Jfong@dadeschools.net

RESULTS:

- Satisfactory
- Incomplete
- Unsatisfactory
- OUT OF BUSINESS

Correct Violations by

- Next Inspection
- 8:00 AM on

BEGIN TIME	END TIME	DATE ASSESSED	POSITION #	EXISTING FACILITIES - PERMIT NUMBER
13:45	15:15	06/01/2015	47452	13-51-1367919

RE-INSPECTION DATE

As per section 120.695 of the Florida Statutes (FS), this form will serve as a "Notice of Non-Compliance: for any violations noted. Items marked below violate the requirements of Chapters 64E-13 and 64E-11 of the Florida Administrative Code (FAC) and must be corrected within the time period indicated in the "Results" section above. Continued operation of this facility without making these corrections is a violation of Chapter 64E-13 and 64E-11, FAC, and Chapter 381, FS. Failure to correct violations may result in an administrative fine or other legal action being initiated or continued.

- | | | | | |
|--|---|---|--|---|
| SCHOOL SANITATION | <input type="checkbox"/> 8. Natural Ventilation | <input checked="" type="checkbox"/> 15. Handwash Facilities | LIQUID/SOLID WASTE | SAFETY |
| <input type="checkbox"/> 1. School Site | <input checked="" type="checkbox"/> 9. Mechanical Ventilation | <input type="checkbox"/> 16. Showers/Fixtures | <input type="checkbox"/> 21. Sewage Disposal | <input type="checkbox"/> 26. First Aid Kit |
| <input type="checkbox"/> 2. Playground Equipment | SANITARY FACILITIES | <input type="checkbox"/> 17. Shower Water Temp. | <input type="checkbox"/> 22. Solid Waste | FOOD |
| <input type="checkbox"/> 3. Athletic Equipment | <input type="checkbox"/> 10. Provided/Accessible | WATER SUPPLY | VECTOR/VERMIN CONTROL | <input type="checkbox"/> 27. Food Insp. Rpt. |
| BUILDINGS | <input type="checkbox"/> 11. Cleanliness & Repair | <input type="checkbox"/> 18. Installed/Operated/Maintained | <input type="checkbox"/> 23. Infestation/Control | OTHER |
| <input type="checkbox"/> 4. Construction | <input checked="" type="checkbox"/> 12. Toilet Facilities | <input type="checkbox"/> 19. Drinking Fountains | <input type="checkbox"/> 24. Brush/Trash | <input checked="" type="checkbox"/> 28. chemicals |
| <input type="checkbox"/> 5. Maintenance & Repair | <input type="checkbox"/> 13. Separation of Sexes | <input type="checkbox"/> 20. Approved Source | <input type="checkbox"/> 25. Water Collection/Drainage | <input checked="" type="checkbox"/> 29. foul odor |
| <input checked="" type="checkbox"/> 6. Lighting/Foot-Candles | <input type="checkbox"/> 14. Fixture Ratio | | | |
| <input type="checkbox"/> 7. Heating, Ventilation, A/C | | | | |

COMMENTS AND INSTRUCTIONS

Violation #6 Replace burned out light bulb 4th floor girls and 3rd floor boys gang bathroom
Code Reference FAC: Lighting/Foot-Candles 64E-13.004(4)(a-d). Illumination in all instructional spaces shall be designed to provide a minimum of forty (40) foot-candles glare free at normal task level. Fixtures shall be so located that there will be uniform (within ten (10) foot-candles) illumination suitable for the activities conducted therein. All required illumination shall be designed so that the failure of any single unit, such as the burning out of an electric bulb will not leave any occupied area or means of egress in darkness. Illumination of chalkboards and other visual aids shall be designed to eliminate glare and shadows.

Violation #9 Restore ventilation in all bathrooms throughout facility
Code Reference FAC: Mechanical Ventilation 64E-13.004(5)(d). All spaces which do not meet the requirements for natural ventilation shall be mechanically ventilated by means of electrically operated exhausts. Fans and blowers shall be sized and designed to provide the required air movement without excessive or disturbing noise. Special provisions shall be made in the design of ventilation systems in areas of high air contamination such as paint shops, auto repair shops and chemistry laboratories, art rooms where kilns are used, wood working, and metal shops, chemical storerooms. A high capacity emergency exhaust system is recommended for chemistry laboratories. All air conditioned spaces shall be ventilated when occupied.

Violation #12 Repair 2 broken urinals boys gang bathroom 4th floor
Code Reference FAC: Toilet Facilities 64E-13.004(6)(a). Toilet facilities shall be accessible under continuous roof cover from all student occupied spaces. In group toilet rooms a partition shall be placed between each water closet. Each compartment shall have a door. Entrances to group toilet rooms shall be provided with a partition or other shielding device to block

Continued On Page 2

INSPECTION CONDUCTED BY: Ella Thompson PHONE: (305) 623-3500 ex. 22822
 INSPECTION COND SIGNATURE: Ella Thompson PHONE 2: (305) 623-3500 ex. 22822
 COPY OF REPORT RECEIVED BY: X JFM DATE: 6/1/2015

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY PUBLIC HEALTH UNIT
Public/Private School



Name: Norman S. Edelcup-Sunny Isles each K-8 Center

Date: 06/01/2015

Identification No: 13-51-1367919

Comments and Instructions (Continued from Page 1):

the occupants from view. Entrance doors shall be self-closing.

Violation #15 Repair hand sink in Rm #149 to drain properly: Currently draining very low

Violation #15

Violation #15 Replace missing faucet fixture (broken) in gang bathroom

Violation #15 Repair broken faucet fixture at hand sink 4th floor girls and 3rd floor boys gang bathroom (No running water)

Code Reference FAC: Handwash Facilities 64E-13.004(6)(b). Handwashing facilities shall be located within or adjoining each toilet room. Soap dispensers shall be provided at all wash basins and liquid or powdered soap shall be used. Individual towels, preferably paper shall be used. Use of common or public towels is prohibited. Hot-air hand drying devices

Violation #28 Keep all chemicals and toxic substance out of reach of children or under lock and key

Code Reference FAC: This applies to any other applicable state or local environmental Health standard enforced by the DOH or the County Health Department.

Violation #29 Eliminate foul odor inside both girls and boys bathroom throughout facility

Code Reference FAC: This applies to any other applicable state or local environmental Health standard enforced by the DOH or the County Health Department.

Copy of Report
Received By: 

Inspector Ella Thompson